









 **POWDER**

KEEP
THIS END UP

**ABC STORED PRESSURE TYPE
MULTIPURPOSE DRY**



MAINTENANCE

- Examine carefully every month.
- Periodically check to ensure that safety seal and tamper indicator are not missing or broken.
- Check that the extinguisher is full by weighing or lifting.
- Check the built-in pressure gauge periodically.
- The green zone is an indicator of the state of readiness of the extinguisher.
- Make sure that discharge hose/ nozzle is unobstructed.

PRECAUTIONS

- Keep this extinguisher in up right position.
- Do not puncture or incinerate even when empty.
- Store away from direct heat.
- Check the seal before use.
- Do not rely on partially used or Discharged Extinguisher.
- In case of Fire break the seal.

RECORD

- Record maintenance and recharge dates on attached Tag

RECHARGE

- If the pressure drops, the needle will shift to the red zone. Immediately Contact 

AGNI HUNTEX PVT. LTD.
(An ISO 9001:2015 Certified Co.) (INDIA)
CIN NO - U28193DL2023PTC022746
Manufacturing by: Ching Industries Pvt. Ltd. ISO 9001:2008 Certified (Co.) (INDIA)

AGNI HUNTEX PVT. LTD.
AGNI HUNTEX PVT. LTD.