



Report No :- WQ/201/2007-4373
Ref Memo No :- HPSAPS/BGS/LI-55/2024-2025
Location :- Aastha Gurukul Academy
Source of Sample :- Drinking Water

GOVERNMENT OF BIHAR
P.H Division, Begusarai
DISTRICT LEVEL DRINKING WATER TESTING LABORATORY
Dt. 16.07.2026
Dt. 14.07.2026
Date of Sampling 14.07.2026
Sample received on - 14.07.2026
Sample Collected by: School Principal

PHYSICO-CHEMICAL TEST REPORT

DISTRICT :- BEGUSARAI			DIVISION:- BEGUSARAI			MONTH:- JULY 2026									
S.N	BLOCK	PANCHAYAT	LOCATION OF SOURCE	PARAMETER											REMARKS
				PH	TURB	EC	TDS	TH	Ca	O	Mg	Alka	Fe	T.CO.U	
1	TEGHRA	PAKTHAUL	AASTHA GURUKUL ACADEMY (RO WATER)												
2	TEGHRA	PAKTHAUL	AASTHA GURUKUL ACADEMY	7.1	1	345	224	108	24	28	13	120	0.2	VE	
				7.5	2	686	446	205	36	44	19	156	0.5	VE	
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500mg/l	200mg/l	75mg/l	250mg/l	30mg/l	200mg/l	1.0mg/l		
Permissible Limit in Absence of Alternative Source as per BIS 10500/2012				NR	5NTU	-	2000mg/l	600mg/l	200mg/l	1000mg/l	100mg/l	600mg/l	NR		


Principal
Aastha Gurukul Academy
Pakthaul Chowk, Barauni
Block-Teghra, Begusarai


MANAGER
Aastha Gurukul Academy
Pakthaul Chauk, Po-Khizirchak
Block-Teghra, Begusarai

